

48505044

Three-phase MID energy meter, 1/5A CT, Modbus protocol



Strong points

- Quick and easy wiring
- MID certification
- Versatile
- Complete ecosystem for easy integration
- Multi-interfaces
- Space-saving

Compliance with standards

- IEC 62053-21
- IEC 62053-23
- IEC 62053-31
- IEC 62052-11
- IEC 61010-1
- EN 50470-1
- EN 50470-3

Link to the reference

COUNTIS P4x are three-phase modular electrical energy meters that enable viewing of the different energies consumed and produced, and also of powers and other measurements directly on the backlit LCD display. They connect indirectly via a wide selection of transformers and current sensors.

They are suitable for use in sub-billing applications thanks to their MID certification.

| C | ıa: | SS | ITI | Ca | a T I | О | n |
|---|-----|----|-----|----|-------|---|---|
| | | | | | | _ | |

| UNSPSC | 41113708 | | | |
|-----------------------|--|--|--|--|
| ETIM Class | EC001506 | | | |
| Commerce | | | | |
| Description | COUNTIS P4x are three-phase modular electrical energy meters that enable viewing of the different energies consumed and produced, and also of powers and other measurements directly on the backlit LCD display. | | | |
| Effective date | 2025-01-01 | | | |
| Offer Life Cycle Code | 40 | | | |
| Country of origin | CN | | | |
| Former product list | 48C03021 COUNTIS M43 3PH CT-1/5A MODBUS 48C03144 COUNTIS M44 3P CT MODBUS MID | | | |

Environmental Sustainability

| PEP Filename | SOCO-00115-V01.01-EN.pdf |
|---|--------------------------|
| Climate change - Total - Cradle to Grave [kg CO ₂ eq.] | 24 |
| Climate change - Total - Cradle to Gate [kg CO ₂ eq.] | 14 |

ETIM - Electrical characteristics

| Nominal current (In) [A] | 6 | |
|-------------------------------|---------------------------------|--|
| Max. current (Imax) [A] | 6 | |
| Nominal voltage (Un) N-L [V] | 184276 | |
| Nominal voltage (Un) L-L [V] | 320480 | |
| Frequency [Hz] | 4555 | |
| Power consumption [W] | 1 | |
| Accuracy class | С | |
| Pole type | Three conductor/four conductor | |
| Energy type | Effective power and blind power | |
| Suitable for | Purchase/supply | |
| Tariff type | Multi-tariff | |
| Tariff control | External | |
| Measurement type load profile | No | |
| Calibrated | Yes | |
| Pulse output | Optical | |
| Pulse type | D0 | |
| Pulse rate [Imp/kWh (kvarh)] | 1010 | |
| | | |

ETIM - Mechanical characteristics

| Escapement mechanism | No |
|-------------------------------------|------------------------|
| Mounting method | DRA (DIN-rail adapter) |
| Width in number of modular spacings | 4 |

2025-03-25 15:29:13



COUNTIS P44 CT1-5A MODBUS MID

| Width [mm] | 72 | | |
|---------------------------|---|--|--|
| Depth [mm] | 65 | | |
| Height [mm] | 94,5 | | |
| With lock code | No | | |
| Degree of protection (IP) | IP20 | | |
| ETIM - Technical features | | | |
| Type of meter | Electronic | | |
| Model | Measurement transformer | | |
| Approval | Measuring Instruments Directive | | |
| Type of indication | Digital | | |
| Type of interface | Modbus | | |
| EEC40 signature | No | | |
| Logistics | | | |
| GTIN/EAN | 3596033319464 | | |
| Customs number | 9028301900 | | |
| SYSTEME | | | |
| ReferenceLabel | 48505044 COUNTIS P44 CT1-5A MODBUS MID | | |
| Technical Characteristics | | | |
| Application | Metering | | |
| Communication protocols | MODBUS | | |
| Model | P44 | | |
| Туре | 3PH CT1-5A, MID | | |

2025-03-25 15:29:13 2/2